

ICC-ES Evaluation Report

ESR-4526

Reissued March 2025

This report also contains:


- [City of LA Supplement](#)

Subject to renewal March 2026

- [CA Supplement](#)

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2025 ICC Evaluation Service, LLC. All rights reserved.

DIVISION: 03 00 00— CONCRETE Section: 03 20 00— Concrete Reinforcing Section: 03 21 00— Reinforcement Bars	REPORT HOLDER: NEUVOKAS CORPORATION	EVALUATION SUBJECT: GATORBAR FIBER- REINFORCED POLYMER (FRP) BAR	
---	--	---	---

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2021 and 2018 [International Building Code® \(IBC\)](#)
- 2021 and 2018 [International Residential Code \(IRC\)](#)

Properties evaluated:

- Physical
- Structural
- Durability

2.0 USES

The GatorBar fiber-reinforced polymer (FRP) bar is used as tension reinforcements in flexural concrete members such as beams, shallow foundations and one-way or two-way elevated slabs, and as vertical reinforcement in concrete columns and walls in normal-weight concrete, as permitted by Section 104.11 of the IBC. The GatorBar FRP bar may also be used where an engineering design is submitted in accordance with IRC Section [R301.1.3](#) and where approved by the building official in accordance with IRC Section [R104.11](#).

3.0 DESCRIPTION

The GatorBar is fiber-reinforced polymer (FRP) bar that is solid and have circular cross section composed of glass fiber embedded in a resin matrix. Available bar size and properties are provided in [Table 1](#) of this report.

4.0 DESIGN AND INSTALLATION

4.1 Design:

The GatorBar must be designed in accordance with ACI CODE 440.11-22, and Chapter 19 of the IBC (ACI 318-19 for 2021 IBC and ACI 318-14 for the 2018 IBC), as applicable. The registered design professional must be responsible for determining, through analysis, the strengths and demands of the structural elements, subject to the approval of the building official.

The following limitations also apply:

1. The GatorBar is limited for use as (a) tension reinforcement in flexural concrete members; (b) vertical reinforcement in concrete columns and walls.
2. The GatorBar is limited to concrete members in normal-weight concrete.

3. The bond coefficient, K_b of the GatorBar must be 1.2.
4. Bent shapes, continuous closed stirrups and ties (hoops) are outside the scope of this report.
5. There is no restriction for the shape of flexural concrete member cross-section (e.g., rectangular, T-shape, L-shape).
6. For multiple bar layers, the relevant provisions for steel reinforcing bar in ACI 318 and ACI CODE 440.11 must also apply to FRP bars, because the FRP bars have no plastic region and the stress in each reinforcing layer varies depending on its distance from the neutral axis. Thus, the analysis of the flexural capacity must be based on a strain-compatibility approach.

4.2 Installation:

The GatorBar FRP bar must be installed in accordance with the approved drawings and specifications. Reinforcement details, including tolerances, reinforcement relation, concrete cover and reinforcement supports, must comply with the applicable provisions in Part 3 of ACI SPEC 440.5-22.

4.3 Special Inspection:

Special inspection is required in accordance with Table 1705.3 of IBC. The special inspector must verify, but are not limited to, the following:

1. The GatorBar is of the type and size specified and is labeled in conformance with this report.
2. The GatorBar is placed within tolerances set forth in ACI SPEC 440.5-22 and are adequately supported and secured to prevent displacement during concrete placement.
3. The minimum concrete cover is provided in accordance with ACI SPEC 440.5-22.
4. The placement, quantity and size of the GatorBar comply with the approved drawings and specifications.

5.0 CONDITIONS OF USE:

The GatorBar described in this report complies with, or is a suitable alternative to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Design and installation must be in accordance with this report, ACI CODE 440.11-22 and the IBC or the IRC, as applicable. In case of conflict, this report governs.
- 5.2 Complete construction documents, including plans and calculations verifying compliance with this report, must be submitted to the code official for each project at the time of permit application. The construction documents must be prepared and sealed by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.3 The fire-resistance rating of the GatorBar reinforced concrete assembly is outside the scope of the evaluation report, and concrete assemblies with GatorBars are limited to Type VB construction under the IBC or IRC.
- 5.4 GatorBar must be stored above the surface of the ground on platforms, skids or other supports as close as possible to the point of placement. If stored outdoors, the GatorBar shall be covered with opaque plastic or other types of cover that will protect the bars from ultraviolet rays.
- 5.5 Use of GatorBar FRP bar in structural members for structures assigned in Seismic Design Categories C through F is permitted when the following conditions are met: (1) structural members are not considered part of the lateral force-resisting system, (2) structural members are not required to be designed to accommodate drifts and forces that occur as the building responds to a seismic event.
- 5.6 Special inspection must be provided in accordance with Section 4.3 of this report.
- 5.7 GatorBar is manufactured under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

Data in accordance with the [ICC-ES Acceptance Criteria for Fiber-reinforced Polymer \(FRP\) Bars for Internal Reinforcement of Concrete Members \(AC454\)](#), dated October 2022, including fiber mass content, moisture absorption and alkaline resistance, and quality control documentation.

7.0 IDENTIFICATION

- 7.1 The ICC-ES mark of conformity, electronic labeling, or the evaluation report number (ICC-ES ESR-4526) along with the name, registered trademark, or registered logo of the report holder must be included in the product label.

- 7.2 In addition, the GatorBar is identified by packaging labeled with the company contact information, product name, bar size, and lot number.
- 7.3 The report holder's contact information is the following:

NEUVOKAS CORPORATION
3206 NUMBER 6 ROAD
AHMEEK, MICHIGAN 49901
(906) 934-2661
www.neuvokascorp.com
matt@neuvokascorp.com

TABLE 1—GATORBAR DIMENSIONS AND PROPERTIES

BAR DESIGNATIO N NUMBER	NOMINAL DIAMETE R (in)	NOMINAL CROSS SECTIONA L AREA (in ²)	MEAN MEASURE D CROSS SECTIONA L AREA (in ²)*	GUARANTEE D ULTIMATE TENSILE FORCE (kip)	MEAN TENSILE MODULUS OF ELASTICIT Y (ksi)	MEAN ULTIMAT E TENSILE STRAIN (%)	GUARANTEE D TRANSVERS E SHEAR STRENGTH (ksi)	GUARANTEE D BOND STRENGTH (ksi)
3	³ / ₈	0.110	0.112	17.1	6810	2.5	27.0	1.40

For SI: 1 inch = 25.4 mm, 1 kip = 4.45kN, 1 psi = 6.89 kPa, 1 ksi = 6.89 MPa

* Mean measured cross sectional area includes surface deformations.

DIVISION: 03 00 00—CONCRETE
Section: 03 20 00—Concrete Reinforcing
Section: 03 21 00—Reinforcement Bars

REPORT HOLDER:

NEUVOKAS CORPORATION

EVALUATION SUBJECT:

GATORBAR FIBER-REINFORCED POLYMER (FRP) BAR

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that the GatorBar fiber-reinforced polymer (FRP) bar, described in ICC-ES evaluation report [ESR-4526](#), have also been evaluated for compliance with the codes noted below as adopted by the Los Angeles Department of Building and Safety (LADBS).

Applicable code editions:

- 2023 *City of Los Angeles Building Code* ([LABC](#))
- 2023 *City of Los Angeles Residential Code* ([LARC](#))

2.0 CONCLUSIONS

The GatorBar fiber-reinforced polymer (FRP) bar, described in Sections 2.0 through 7.0 of the evaluation report [ESR-4526](#), comply with the LABC Chapter 19, and the LARC, and are subject to the conditions of use described in this supplement.

3.0 CONDITIONS OF USE

The GatorBar fiber-reinforced polymer (FRP) bar, described in this evaluation report supplement must comply with all of the following conditions:

- All applicable sections in the evaluation report [ESR-4526](#).
- The design, installation, conditions of use and identification of the fiber-reinforced polymer (FRP) reinforcing bar are in accordance with the 2021 *International Building Code*® (IBC) provisions noted in the evaluation report [ESR-4526](#).
- The design, installation and inspection are in accordance with additional requirements of LABC Chapters 16 and 17, as applicable.
- Under the LARC, an engineered design in accordance with LARC Section R301.1.3 must be submitted.

This supplement expires concurrently with the evaluation report, reissued March 2025.

DIVISION: 03 00 00—CONCRETE
Section: 03 20 00—Concrete Reinforcing
Section: 03 21 00—Reinforcement Bars

REPORT HOLDER:**NEUVOKAS CORPORATION****EVALUATION SUBJECT:****GATORBAR FIBER-REINFORCED POLYMER (FRP) BAR****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that GatorBar fiber-reinforced polymer (FRP) bar, described in ICC-ES evaluation report ESR-4526, has also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2022 *California Building Code* (CBC)

For evaluation of applicable chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

- 2022 *California Residential Code* (CRC)

2.0 CONCLUSIONS**2.1 CBC:**

The GatorBar fiber-reinforced polymer (FRP) bar, described in Sections 2.0 through 7.0 of the evaluation report ESR-4526, complies with CBC Chapter 19, provided the design and installation are in accordance with the 2021 *International Building Code*® (IBC) provisions noted in the evaluation report and the additional requirements of CBC Chapters 16, 17 and 19, as applicable.

2.1.1 OSHPD:

The applicable OSHPD Sections and Chapters of the CBC are beyond the scope of this supplement.

2.1.2 DSA:

The applicable DSA Sections and Chapters of the CBC are beyond the scope of this supplement.

2.2 CRC:

The GatorBar fiber-reinforced polymer (FRP) bar, described in Sections 2.0 through 7.0 of the evaluation report ESR-4526, complies with CRC Section R301.1.3, provided the design and installation are in accordance with the 2021 *International Residential Code*® (IRC) provisions noted in the evaluation report and the additional requirements of CRC Chapter 3.

This supplement expires concurrently with the evaluation report, reissued March 2025.