



ALLEN COUNTY, INDIANA BUILDING DEPARTMENT

200 E. Berry Street/Suite 180

FORT WAYNE, INDIANA 46802-1299

PHONE: (260) 449-7131

FAX: (260) 449-7596

JOHN E. CAYWOOD, Building Commissioner

December 16, 2019

Mr. Matt Kero  
VP of Engineering  
Neuvokas Corporation

**Re: Basalt Fiber Reinforced Polymer (BFRP) Rebar as an Alternative to Steel Reinforcement**

Dear Mr. Kero,

After review of the product and literature provided, GatorBar #3 (BFRP Rebar) is permitted for use and is code compliant in Allen County for the following applications:

- Flatwork
- Foundations
- Stem walls

The use of GatorBar rebar in any other type of project will be reviewed on a case-by-case basis by the appropriate personnel.

Thank you,

A handwritten signature in blue ink, which appears to read "John E. Caywood", is written over the typed name and title.

John E. Caywood  
Allen County Building Commissioner